



Ref. Certif. No.

SE-110922**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Moulded Case Circuit-Breakers

Name and address of the applicant

LS ELECTRIC Co., Ltd.
LS Tower, 127 LS-ro, Dongan-gu, Anyang-si, Gyeonggi-Do,
14119, Republic of Korea

Name and address of the manufacturer

Shanghai Yongji Electrical Co., Ltd.
No. 2239, South Jinshi Road, Jinshanwei Town,
Jinshan District, Shanghai, P.R. China

Name and address of the factory

Same as manufacturer

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

Ue= 230V~ for 1P, 400V~ for 2P, 3P
In= 5, 10, 15, 20, 25, 30, 40, 50A
Icu= 10kA, Ics= 7,5kA
Cat. A. Ui=690V. Uimp= 6kV. 50/60Hz. Ii= 10In

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

BFN

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

230200417SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden
Date: 28 April, 2023

Signature:

Leif Mattsson